



ITEM NUMBER	DESCRIPTION	FURNISHED BY		INSTALLED BY	
		O.G.& E.	CONSUMER	O.G.& E.	CONSUMER
1	Service Lateral	X		X	
2	Service Lateral Raceway		X		X
3	Meter Base	X			X
4	Service Raceway		X		X
5	Service Equipment		X		X
6	Meter	X		X	
*7	Grounding Electrode & Grounding Electrode Conductor		X		X

* Not Shown

Notes:

1. When foundation obstructions exist, the use of schedule 40 (minimum) conduit with (2) 45-degree elbows to clear obstructions is permissible. The top 45-degree elbow is to be below ground level.
2. OG&E equipment is to be installed on outside surface of structure and is not to be recessed.
3. Refer to U16 for proper identification and marking.
4. OG&E equipment not to be used for customer grounding.

**METER INSTALLATION
FOR SELF-CONTAINED SINGLE PHASE OR THREE PHASE METER
208Y/120 OR 240Δ /120 OR 240/120 VOLTS
400-AMPERES MAXIMUM**