



- Note:**
- A. Source and load conductors in separate conduits for overhead service
 - B. Diameter of pole at ground line is to be a minimum of 7-inches.
 - C. 12-ft over areas restricted to pedestrians or other traffic less than 8-ft in height. 16-ft over areas subject to any traffic greater than 8ft. in height. For swimming pools see D262.4 or D262.6. For other situations see D262, D262.1, D262.4 or D262.5.

ITEM NO.	DESCRIPTION	FURNISHED BY		INSTALLED BY	
		O.G.E.	CONSUMER	O.G.E.	CONSUMER
1	Meter base	X			X
2	Meter	X		X	
‡ 3	Service pole		X		X
4	Service head		X		X
5	Service entrance conductor		X		X
6	Service drop	X		X	
7	Service drop bracket	X			X
8	Service raceway		X		X
9	Service wires		X		X
10	Service wiring bracket		X		X
11	Grounding electrode Conductor		X		X
12	Grounding electrode		X		X

‡ Pressure treated southern yellow pine

The following is a suggested configuration for meter bases for overhead and underground meters in residential and commercial applications. OG&E Energy Corp., its subsidiaries and affiliates disclaim any liability for the construction or maintenance practices relating to such suggested configuration.

APPROVED

SUPERSEDES FEB 2007 ISSUE

**CONSUMER SERVICE POLE
200-AMPERE MAXIMUM PER METER**