



Notes:

- 1 Total length of pole is to be a minimum of 18 feet and diameter of pole at ground line is to be a minimum of 7-inches.
- 2 Disconnect cabinet to be locked by OG&E.
- 3 OG&E to secure Energized Parts and Switch Position with Series 1 lock (301236).

NOTES:

- A. 12-ft over areas restricted to pedestrians or other traffic less than 8-ft in height.
16-ft over areas subject to any traffic greater than 8ft. in height.
For swimming pools see D262.4 or D262.6.
For other situations see D262, D262.1, D262.4 or D262.5.

B. Use 1/2" thru bolts on top and bottom to mount meter base.

Item no.	DESCRIPTION	Furnished by		Installed by	
		O.G.E.	Consumer	O.G.E.	Consumer
1	Service head		X		X
‡ 2	Service pole See note A		X		X
3	200 Amp Fused Disconnect		X		X
4	Meter base	X			X
5	Service entrance conductor		X		X
6	Service raceway		X		X
7	Service drop bracket	X			X
8	Service drop	X		X	
9	Meter	X		X	
10	Grounding electrode Conductor		X		X
11	Grounding electrode		X		X
12	Disconnect Switch		X		X
13	1/2" Mounting bolts See note B		X		X

‡ Pressure treated southern yellow pine

**ALTERNATE
480V CONSUMER SERVICE POLE
REFER TO U773.8 FOR PRIMARY CHOICE**