



**NOTE:**

- A. 12-ft over areas restricted to pedestrians or other traffic less than 8-ft in height.
- 16-ft over areas subject to any traffic greater than 8ft. in height.
- For swimming pools see D262.4 or D262.6.
- For other situations see D262, D262.1, D262.3 or D262.5.

**\* Refusal to attach service to inadequate structure is determined by OG&E installer based on but not limited to pole size and type, bracing, and attachment height.**

| ITEM NO. | DESCRIPTION                   | FURNISHED BY |          | INSTALLED BY |          |
|----------|-------------------------------|--------------|----------|--------------|----------|
|          |                               | O.G.& E.     | CONSUMER | O.G.& E.     | CONSUMER |
| 1        | METER BASE                    | X            |          |              | X        |
| 2        | METER                         | X            |          | X            |          |
| 3        | SERVICE EQUIPMENT             |              | X        |              | X        |
| 4        | *SERVICE DROP                 | X            |          | X            |          |
| 5        | SERVICE DROP BRACKET          | X            |          |              | X        |
| 6        | SERVICE RACEWAY               |              | X        |              | X        |
| 7        | SERVICE ENTRANCE CONDUCTOR    |              | X        |              | X        |
| 8        | CONSTRUCTION POLE             |              | X        |              | X        |
| 9        | GROUNDING ELECTRODE CONDUCTOR |              | X        |              | X        |
| 10       | GROUNDING ELECTRODE           |              | X        |              | X        |
| 11       | POLE BRACES                   |              | X        |              | X        |

**TEMPORARY SERVICE  
3 WIRE SINGLE-PHASE 240/120-VOLTS**

APPROVED  
SUPERSEDES FEB 2007 ISSUE