



- Note:**
- A. Source and load conductors in separate conduits for overhead service
 - B. Diameter of pole at ground line is to be a minimum of 7-inches.
 - C. 12-ft over areas restricted to pedestrians or other traffic less than 8-ft in height, 16-ft over areas subject to any traffic greater than 8ft. in height. For swimming pools see D262.4 or D262.6. For other situations see D262, D262.1, D262.4 or D262.5.
 - D. Use 1/2" thru bolts on top and bottom to mount meter base.

ITEM NO.	DESCRIPTION	FURNISHED BY		INSTALLED BY	
		O.G.E.	CONSUMER	O.G.E.	CONSUMER
1	Meter base	X			X
2	Meter	X		X	
‡ 3	Service pole		X		X
4	Service head		X		X
5	Service entrance conductor		X		X
6	Service drop	X		X	
7	Service drop bracket	X			X
8	Service raceway		X		X
9	Service wires		X		X
10	Service wiring bracket		X		X
11	Grounding electrode Conductor		X		X
12	Grounding electrode		X		X
13	1/2" Mounting bolts See note D		X		X

‡ Pressure treated southern yellow pine

CONSUMER SERVICE POLE 200-AMPERE MAXIMUM PER METER

Signatures on File

APPROVED

SUPERSEDES JUL 2018 ISSUE