



Notes:

- A. 12-ft clearance over areas Restricted to Pedestrians or Traffic less than 8-ft in height.
- B. No other joint attachments allowed.
- C. To serve single customer only.
- D. All poles are to be deemed climbable by OG&E.
- E. Customer's load wire shall be terminated on the "load side" of the Ct's (point of delivery).
- F. For customer load greater than 480 Amp, Refer to U773.10.
- G. Foam poles if within 25% of max span.

	Max Amps Per Phase	Max Span 30' 6"	Max Span 35' 5"	Max Span 40' 3" Set 8' deep
4/c-0ALSSC	200	65	75	85
4/c-000ALSSC	260	55	60	70
4/c-350ALSSC	420	45	50	60
4/c-500ALSSC	480	35	40	50

OVERHEAD CT RATED METER INSTALLATION 480 OR 480 WYE/277-VOLTS 600AMP RATED