NOTES:

- A. Consumer shall leave 6-ft of cable beyond point Z
- B. Use Schedule 40 PVC or better
- letails on
- um of 18-inches



7	6	C. Refer to U748 and U748.1 for de terminations in pedestal
9	4	D. Conduit should extend a minimu below grade
48 to 66-in 60-in preferred	* ·	3-ft (min) 5 C
	2 B	A 6
3-ft (min) = = = = = = = = = = = = = = = = = = =	D 1	24 E
8		

ITEM		FURNISHED BY		INSTALLED BY	
NUMBER	DESCRIPTION	O.G.&E.	CONSUMER	O.G.&E.	CONSUMER
1	Temporary Service Lateral		Х		Х
2	Service Lateral Raceway		X		X
3	Meter Base	Х			X
4	Meter	X		X	
5	Service Pedestal	Х		Х	
6	Service Equipment		Х		X
7	Treated Support		X		Х
8	Grounding Electrode		X		Х
9	Grounding Electrode Conductor		X		x

TEMPORARY SERVICE 3-WIRE, SINGLE-PHASE 240/120-VOLTS