



Galvanized rigid 3-inch pipe is to be concreted into ground at a minimum depth of 30-inches with a minimum of 6-inches of concrete surrounding pipe.

ITEM Number	DESCRIPTION	FURNISHED BY		INSTALLED BY	
		O.G.&E.	CONSUMER	O.G.&E.	CONSUMER
1	Service Lateral	X		X	
‡ 2	Service Lateral Raceway & 90° Bend		X		X
3	CT Meter Base	X			X
4	Conduit and wire		X		X
5	3-inch Galvanized Rigid Pipe set in concrete		X		X
6	Metering Conduit 1-inch sch 40		X		X
7	Meter	X		X	
*8	CT Cabinet	X			X
9	1 5/8-inch Kindorf and Clamps		X		X

‡ Size and number of conduits as specified by OG&E

\* Secondary Connection Box shall be bonded to neutral block

Notes

1. Place caps on top of pipes to keep moisture from inside of pipe to prevent deterioration.
2. Pipe to be galvanized rigid 3-inch pipe. Pipe to be set at a minimum depth of 30-inches with a minimum of 6-inches of concrete surrounding pipe.
3. Refer to U16 for proper identification and marking.
4. In order for the meter to be accessible for operation and maintenance, a minimum of 4 feet clearance from all obstructions must be maintained in front of the meter.

**CT METERING COMPONENTS  
INSTALLATION INSTRUCTIONS  
ONE CUSTOMER AND CTS IN CT CABINET  
SINGLE-PHASE OR THREE-PHASE**

The following is a suggested configuration for meter bases for overhead and underground meters in residential and commercial applications. OG&E Energy Corp., its subsidiaries and affiliates disclaim any liability for the construction or maintenance practices relating to such suggested configuration.

APPROVED **Signatures on File**  
SUPERSEDES MAY 2016 ISSUE