



- Note:**
- A. Source and load conductors in separate conduits for overhead service
  - B. Diameter of pole at ground line is to be a minimum of 7-inches.
  - C. 12-ft over areas restricted to pedestrians or other traffic less than 8-ft in height. 16-ft over areas subject to any traffic greater than 8ft. in height. For swimming pools see D262.4 or D262.6. For other situations see D262, D262.1, D262.4 or D262.5.
  - D. Use 1/2" thru bolts on top and bottom to mount meter base.

ITEM NO.	DESCRIPTION	FURNISHED BY		INSTALLED BY	
		O.G.E.	CONSUMER	O.G.E.	CONSUMER
1	Meter base	X			X
2	Meter	X		X	
‡ 3	Service pole		X		X
4	Service head		X		X
5	Service entrance conductor		X		X
6	Service drop	X		X	
7	Service drop bracket	X			X
8	Service raceway		X		X
9	Service wires		X		X
10	Service wiring bracket		X		X
11	Grounding electrode Conductor		X		X
12	Grounding electrode		X		X
13	1/2" Mounting bolts See note D		X		X

‡ Pressure treated southern yellow pine

## CONSUMER SERVICE POLE 200-AMPERE MAXIMUM PER METER

The following is a suggested configuration for meter bases for overhead and underground meters in residential and commercial applications. OGE Energy Corp., its subsidiaries and affiliates, disclaim any and all liability for the construction or maintenance practices relating to such suggested configuration. Each individual, company, or entity engaging the work associated with this configuration bears full responsibility for its, his, or her own occupational training, and compliance with all applicable local, state, and national laws and regulations. The configuration is not intended to replace the trainin know-how or instruction that ma be needed for safe construction or maintenance.  
 APPROVED Signatures on File  
 SUPERSEDES JUL 2018 ISSUE