



Questions and Answers

For OG&E's 2024 All Source RFP

Question #1

Will OG&E consider solar assets in the 9.5-9.9MW capacity range as meeting minimum nameplate capacity per Section 1, Table 1?

A: *No. The minimum nameplate Capacity of any Project, including solar, is 10 MW as noted in Section 1, Table 1 of the 2024 All Source RFP Document.*

Question #2

Our team is going to attend the Technical Conference. Are the invites unique, do we need to submit a full list of attendees and email addresses?

A: *All attendees interested in joining the Technical Conference may register by emailing 2024AllSourceRFPComm@oge.com prior to 3 PM on May 20, 2024. Bidders may submit a list of attendees along with their email addresses for registration.*