

U762.9

UNDERGROUND STANDARD
FEB 2012



Meter Base 1010183
Furnished by OG&E
Installed by
Consumer

Service lateral
conductors
(furnished,
installed and
connected by
OG&E)

See
note 2

Place
instructions as to
where service is
coming from.

Service entrance
conductors
(furnished and
installed by
consumer,
connected by
OG&E)

3-in Schedule 40 PVC
or better Furnished
and Installed by
Consumer

Plastic bushing
required for steel
conduit to protect
cable

Notes:

1. For 277/480 refer to U765 and U765.1 for installation
2. Place identifying tag on service conductors with information relating to where service is coming from (pedestal, transformer, pipe or no pipe under driveway.) Refer to U16.

CONNECTION DIAGRAM THREE PHASE 320 AMPERE MAXIMUM SERVICE VOLTAGE 120/240 AND 120/208-Volts

SUPERSEDES SEP 2007 ISSUE

APPROVED **Signatures on File**

The following is a suggested configuration for meter bases for overhead and underground meters in residential and commercial applications. OG&E Energy Corp., its subsidiaries and affiliates disclaim any liability for the construction or maintenance practices relating to such suggested configuration.