



NOTES:

- A. 12-ft over areas restricted to pedestrians or other traffic less than 8-ft in height.
16-ft over areas subject to any traffic greater than 8ft. in height.
For swimming pools see D262.4 or D262.6.
For other situations see D262, D262.1, D262.3 or D262.5.
- B. Use 1/2" thru bolts on top and bottom to mount meter base.

* Refusal to attach service to inadequate structure is determined by OG&E installer based on but not limited to pole size and type, bracing, and attachment height.

ITEM NO.	DESCRIPTION	FURNISHED BY		INSTALLED BY	
		O.G.& E.	CONSUMER	O.G.& E.	CONSUMER
1	METER BASE	X			X
2	METER	X		X	
3	SERVICE EQUIPMENT		X		X
4	*SERVICE DROP	X		X	
5	SERVICE DROP BRACKET	X			X
6	SERVICE RACEWAY		X		X
7	SERVICE ENTRANCE CONDUCTOR		X		X
8	CONSTRUCTION POLE		X		X
9	GROUNDING ELECTRODE CONDUCTOR		X		X
10	GROUNDING ELECTRODE		X		X
11	POLE BRACES		X		X
12	1/2" Mounting bolts See note B		X		X

**TEMPORARY SERVICE
3 WIRE SINGLE-PHASE 240/120-VOLTS**